

From: [Planning.APEast](#)
Sent: 24 January 2022 07:58
To: [planappconsult](#)
Subject: PAP/2021/0663 - Land On The North East of J10 M42 Dordon/A5 Polesworth CRM:0038834

For the attention of Andrew Collinson

Our Ref: P-211214-34310

Good Morning,

Re: Application No. PAP/2021/0663
Site Address : Land On The North East of J10 M42 Dordon/A5 Polesworth

With reference to the above planning application the Company's observations regarding sewerage are as follows.

Foul is proposed to connect into the public foul water sewer, which will be subject to a formal section 106 sewer connection approval. As a pumped solution is being proposed for foul water discharge from this site, a sewer modelling study may be required to determine the impact this development will have on the existing system and if flows can be accommodated. Severn Trent may need to undertake a more comprehensive study of the catchment to determine if capital improvements are required. If Severn Trent needs to undertake capital improvements, a reasonable amount of time will need to be determined to allow these works to be completed before any additional flows are connected.

Surface water is proposed to discharge into a watercourse, which we have no comment. Please note that It is advised to discuss surface water proposals with the Lead Local Flood Authority for their requirements or recommendations regarding acceptable disposal methods or flow rates.

For the use or reuse of sewer connections either direct or indirect to the public sewerage system the applicant will be required to make a formal application to the Company under Section 106 of the Water Industry Act 1991. They may obtain copies of our current guidance notes and application form from either our website (www.stwater.co.uk) or by contacting our Developer Services Team (Tel: 0800 707 6600).

Suggested Informative

Severn Trent Water advise that although our statutory sewer records do not show any public sewers within the area you have specified, there may be sewers that have been recently adopted under, The Transfer Of Sewer Regulations 2011. Public sewers have statutory protection and may not be built close to, directly over or be diverted without consent and you are advised to contact Severn Trent Water to discuss your proposals. Severn Trent will seek to assist you obtaining a solution which protects both the public sewer and the building.

Should you require any further information please contact us on email below.

Kind regards,

Asset Protection Team

Asset Protection
Asset Strategy and Planning
Chief Engineer
Severn Trent Water Ltd

Email: planning.apeast@severntrent.co.uk

Severn Trent Plc (registered number 2366619) and Severn Trent Water Limited (registered number 2366686) (together the "Companies") are both limited companies registered in England & Wales with their registered office at Severn Trent Centre, 2 St John's Street, Coventry, CV1 2LZ This email (which includes any files attached to it) is not contractually binding on its own, is intended solely for the named recipient and may contain CONFIDENTIAL, legally privileged or trade secret information protected by law. If you have received this message in error please delete it and notify us immediately by telephoning +44 2477715000. If you are not the intended recipient you must not use, disclose, distribute, reproduce, retransmit, retain or rely on any information contained in this email. Please note the Companies reserve the right to monitor email communications in accordance with applicable law and regulations. To the extent permitted by law, neither the Companies or any of their subsidiaries, nor any employee, director or officer thereof, accepts any liability whatsoever in relation to this email including liability arising from any external breach of security or confidentiality or for virus infection or for statements made by the sender as these are not necessarily made on behalf of the Companies. Reduce waste! Please consider the environment before printing this email